

Konformitätserklärung

Attestation de conformité à la commande
Certificate of compliance with the order

VDI 6022

Hiermit erklären wir, dass unsere nachstehend zertifizierten Produkte **konform sind zu den Anforderungen der VDI 6022 Raumlufttechnik, Raumluftqualität hinsichtlich der Hygieneanforderungen an Raumluft-technische Anlagen und Geräte (VDI-Lüftungsregel)** (immer unter der Voraussetzung, dass sie bestimmungsgemäß eingesetzt werden).

We herewith declare that our below specified product series are fully in compliance to the requirements of VDI 6022 Ventilation and indoor-air quality regarding hygiene requirements for ventilation and air-conditioning systems and units (VDI Ventilation CODE of Practice) (always under the condition that they are used as intended).

Modelle/ Series	Medium/ Media	Filterklassen/ Filter class
FP, EC, ECG, SK, SKG, NK, S, SG, N, DMA, DMB, DMC, DKA, DKB, DKC, DFA, DFB, DFC	Filtermedien/filter media: Synthetik, nassgelegtes Glas, PTFEMembran/ synthetic, wetlaid Glass, PTFE-membrane Rahmen/frame: Plastik, Aluminium, Stahl, Edelstahl/ plastic, aluminium, steel, stainless steel Dichtung/gasket: geschlossenporig/ closedporous	acc. ISO16890, EN1822, EN779

Weitherhin sind die oben genannten Filter konform zu den folgenden Normen und technischen Regelwerken:

Furthermore, the filters comply with the harmonized standards specified below:

ISO 16890	Particulate air filters for general ventilation Determination of the filtration performance
EN 1822	High Efficiency Air Filters (EPA, HEPA, ULPA)
VDI 6022	Ventilation and indoor-air quality – Hygiene requirements for ventilation and air-conditioning systems and units
DIN EN 16789-3	Ventilation for non-residential buildings – performance requirements
VDI 3803-4	Air-conditioning system requirements – Air filter systems
SWKI VA 101-01	Classification, test methods and applications for air filters
SWKI VA 104-01/02	Hygienic requirements for air conditioning systems

Gültig von-bis/valid from-to: 01 Jan 2020 - 30 Jun 2021

Dortmund, 01.06.2020, Qualitätsbeauftragter



EURO-Filter GmbH



Riesestraße 20
44287 Dortmund

0231 720892-0 • 0231 720892-99 • info@euro-filter.de

